



Office of the Zoning Administrator
417 E. Fayette Street, Benton Bldg., Room 147

Ref: 1817 N. Broadway

Date: September 11, 2024

This memo is submitted to confirm the review of a request from the owner and/or representative of the property (or properties) referenced above for authorization to:

Convert existing premises into four dwelling units - R-8 Zoning District

Please be advised that the Office of the Zoning Administrator has determined that the authorization requested above (in whole or in part) requires approval by Ordinance of the Mayor and City Council of Baltimore. In the furtherance of said Ordinance approval, the Zoning Administrator has determined that the following variances per the Zoning Code of Baltimore City are required or needed to be incorporated into the bill for approval.

- For four dwelling units, at least three off-street parking spaces are required. The rear of the property does not appear to be able to accommodate the required off-street parking spaces, therefore, a variance will be needed. (Subsection 9-703(f), Table 16-406)
- The required lot area for four dwelling units is 2,625 square feet. The existing lot is approximately 1,251 square feet. (Subsection 9-703(d), Table 9-401). Therefore a variance will be needed.

This memo is being submitted in accordance with Subsections 5-201 and 5-303 of the Zoning Code for Baltimore City.

Respectfully,

Geoffrey M. Veale
Zoning Administrator

cc: Department of Legislative Reference
A Rod Womack, Applicant
Councilmember Robert Stokes
Department of Planning