

APPROVED FOR FORM
STYLE, AND TEXTUAL SUFFICIENCY
8-2-18
DEPT LEGISLATIVE REFERENCE

AMENDMENTS TO COUNCIL BILL 18-0259
(1st Reader Copy)

By: Judiciary and Legislative Investigations Committee

Amendment No. 1

On page 1, in line 2, strike “**Repealing Appendix D**” and substitute “**Fire Apparatus Access Roads**”; in line 4, after the semi colon, insert “requiring consideration of the National Association of City Transportation Officials (NACTO) Urban Street Design Guide for fire apparatus access roads;”; and, on the same page, in line 7, after “Appendices”, insert “and § 503.2.1”.

Amendment No. 2

On page 2, after line 25, insert

“Chapter 5. Fire Service Features

Sections 501 to 502 [504] {As in IFC}

Section 503 Fire Apparatus Access Roads

503.2 Specifications. Fire apparatus access roads shall be installed and arranged in accordance with Sections 503.2.1 through 503.2.8.

503.2.1 Dimensions. Fire Apparatus access roads shall have an unobstructed width of not less than 20 feet (6096 mm), exclusive of shoulders, except for approved security gates in accordance with Section 503.6 and an unobstructed vertical clearance of not less than 13 feet 6 inches (4115 mm).

EXCEPTIONS: PUBLIC STREETS SHALL BE IN ACCORDANCE WITH THE NATIONAL ASSOCIATION OF CITY TRANSPORTATION OFFICIALS (NACTO) URBAN STREET DESIGN GUIDE.

SECTION 504 {AS IN IFC}”.

ADOPTED